

## 🌄 ЈКС

#### FLY ASH MANAGEMENT IN CPP & REDUCTION IN FOSSIL FUEL CONSUMPTION

#### Brief Description:

- > Three types of ash generation viz. Bed ash, Dry fly ash (fine) and Dry fly ash (coarse).
- ▶ LOI in the range of 0.5 to 15 %.
- During Indonesian coal firing, LOI is observed as below:

1. Bed Ash - 0.5 to 0.6 %

- 2. Dry Fly Ash (Fine) 5 to 6 %
- 3. Dry Fly Ash (Coarse) 7 to 15 %
- Our target is 100 % dry fly ash utilization.
- > Dry fly ash (fine) was only been able to use.
- > Dry fly ash (coarse) was not able to use in cement manufacturing due to high LOI 7 to 15 %.
- ▶ ESP section fine ash LOI 5 to 6 %.
- ▶ Both Economizer (ECO) & Air Pre Heater (APH) section coarse ash LOI 7 to 15 %.
- > Several brain storming experiment / trail were conducted to meet out the target.

## 🌄 ЈКС

### TRIGGER OF THE PROJECT

- > Dry fly ash is directly mixed-up with final product of cement with certain ratio.
- ▶ Improves workability, durability, cohesiveness and ultimate strength.
- > Part of fly ash (High LOI) was not able to use in cement manufacturing.
- ▶ High LOI in ash causing lower efficiency of boiler and high fossil fuel consumption.
- > Initiatives are pride to manufacture the green cement and healthy atmosphere.
- ▶ Improved CPP Fly ash Quality increases reactive SiO2 content with higher fineness.
- > By Improved Fly ash, Clinker Factor got reduced and resulted into CO2 reduction.

# 🏷 ЈКС


#### CHALLENGES FACED & BRIEF ON COUNTERING

- Fly ash (coarse) with high LOI (7 to 15 %) was unable to use in Cement plant.
- ► Ash composition parameters and data collection carried out in all ash collection hoppers like Bed ash, ECO & APH and ESP fields.
- > Data collection in various load pattern and tabulated for ease study.
- **ESP** section fine ash LOI is 5 to 6 %.
- ▶ Both ECO & APH section coarse ash LOI is 7 to 15 %.
- > Separate Study carried out in these two ash collection points and analyzed.
- **ECO** section ash LOI 5 to 7 % with less fine particles.
- > APH section ash LOI 7 to 15 % with more coarse particles.


## 🄊 ЈКС


#### CHALLENGES FACED & BRIEF ON COUNTERING

- **ESP** fields ash is being transported towards Silo 1.
- **ECO & APH** ash was being transported thro' common conveying line towards Silo 2.
- > Decided to merge ECO section ash along with ESP fields' ash at silo 1.
- Fine fly ash Quantity increased.
- > APH Section coarse ash was diverted/re-circulated into furnace.
- > APH section ash conveying system was modified to recirculate the coarse ash.
- > Various trials and experiments were carried out.
- Finally, started to get low LOI ash in regular basis irrespective of plant load.
- > Regularly shifting to cement plant through bulker for PPC manufacturing.
- Ash dumping is totally been avoided.



| Project Cost            | Tangible Benefits | Savings   | Saving      | Pay Back     |
|-------------------------|-------------------|-----------|-------------|--------------|
| (in Lakhs)              |                   | (in UOM ) | (INR Lakhs) | (Years)      |
| 2,00,000<br>(MS piping) | Savings of Coal   | 2 MT/Day  | 21 Lacs PA  | One<br>Month |





# 🀬 ЈКС

REPLICATION POTENTIAL OF PROJECT WITHIN SECTOR


- ► APH Section coarse ash was diverted/re-fed into boiler furnace thro' available peephole opening (just above fluidization bed) by modified ash conveying system.
- Various trials and experiments were carried out, finally started to get low LOI ash on regular basis irrespective of plant load and shifting to cement plant through bulker for PPC manufacturing and ash dumping is totally been avoided.
- After installation in our JK Cement, Muddapur (Karnataka) Unit, same project has been implemented in our unit like JK Cement Works, Nimbahera (Rajasthan) and getting results successfully.


## 🔊 ЈКС

## ACHIEVING NATIONAL BENCHMARKS / STANDARDS

| Parameters | UOM   | IS NORMS (IS 3812) | CPP FLY ASH |
|------------|-------|--------------------|-------------|
| LOI        | %     | 5 (Max)            | 4.5-5.0     |
| SiO2       | %     | 35 (Min)           | 56-62       |
| SO3        | %     | 3 (Max)            | 0.2-0.3     |
| LR         | N/mm2 | 4.5 (Min)          | 6.5         |
| Na2O       | %     | 1.5 (Max)          | 0.07        |
| Blaine     | M2/kg | 320 (Min)          | 340         |
| Chloride   | %     | 0.05 (Max)         | 0.004       |

12





# SINC ENVIRONMENTAL PERFORMANCE EVALUATION

- Dry Fly ash (coarse) around 2500 MT per year was being drained from SILO and dumped as wet pond ash at back yard.
- > The ash was been fed into boiler by mixing with coal after dried out.
- > Other resources like vehicle, manpower, fuel, water and land was been used.
- After implementation of the ash re-feeding system into boiler furnace, the following benefits achieved:
- 1) Water required for wet pond ash draining was saved around **1250 M3 per year.**
- 2) Dumping area of around **800 M2** was being freed and the same is being used for green development.
- 3) The additional utilization of resources like fuel, manpower and vehicles was totally avoided.



16